

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 16/4/26

It is certified that an inspection team headed by Dr. N.S. Dural
(Name of Officers with designation) from Deputy Controller PHED inspected
the Mount View Sr. Sec. School, Badwas. (Name & Address of the school)
on Badwas. (date of inspection) and on the basis of Water Test Report (Attached) bearing
no. Lab/Tech (Chem) 1022/19 dated 07-04-2026 of Water Testing Laboratory.
(PHED Lab) certified that the Mount View Sr. Sec. School, Badwas. (Name
of school) has safe drinking water facilities for the students and members of staff of the
institution. School is also maintains the hygienic sanitation condition in the school building &
the campus as per norms prescribed by the Central/State/UT. Govt.

This certificate is valid till 31/3/2027

C-A

Signature with Seal :

Name :

Designation :

Name & Address of the Office/ Department :

Dr. Narendra Singh Deval
Deputy Controller
Satellite Hospital, Hiran Magri
Sector-6, Udaipur (Raj.)
RMC No. 17973

To

The Principal
Mount View Sr. Sec. School

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/ PHED Lab/local bodies

OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, REGIONAL LAB UDAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech(Chem)/2026-27/ **19**

Date **07/04/2026**

To,
Principal
Mount View Sr.Sec.School
Plot No.2,2A,1-Shreenath Nagae Near Transport Nagar Airport Road
Bedwas,Udaipur
Soure-Tap Ro Water

**The Sample was not
Collected by this Laboratory**

Ref:- Your Letter No.545 Dated 06/04/2026

Received Date :06/04/2026

**Not Valid for Water
Quality Legal Cases**

Lab Sample No.				31
Source & Location		Desirable Limit as Per IS 10500:2012	Permissible Limit in absence of Alternate Source IS 10500:2012	Tap Ro Water Mount View Sr.Sec.School Plot No.2,2A,1- Shreenath Nagar Near Transport Nagar Airport Road
				Bedwas,Udaipur
				06.04.2026
Village/Town				
Date Of Collection				
1	pH	6.5-8.5	6.5-8.5	6.8
2	Turbidity N.T.U.	1.0	5.0	0.4
3	Temperature (°C)	*	*	*
4	Colour (Hazen Units)	*	*	*
5	Odour	*	*	*
6	Total Alkalinity (as Na ₂ CO ₃)	200	600	100
7	Total Hardness (as CaCO ₃)	200	600	128
8	Calcium Hardness(as CaCO ₃)			68
9	Magnesium Hardness(as CaCO ₃)			60
10	As Calcium Ca ⁺⁺	75	200	27.25
11	As Magnesium Mg ⁺⁺	30	100	14.58
12	Chloride (as Cl ⁻)	250.0	1000	40
13	Sulphate (as SO ₄ ⁻²)	200.0	400	*
14	Nitrite (as NO ₂ ⁻)	45.0	45	9.2
15	Total Dissolved Solids	500.0	2000	315
16	Fluoride (as F ⁻)	1.0	1.5	0.52

Note:- All Results Except Sr.No. 1 are in mg/L.


Superintending Chemist
PHED Regional Lab,Udaipur
07/04/2026



Office of the Superintending Chemist
Public Health Engineering Department, Rajasthan
Regional Laboratory, Udaipur
Report of the Bacteriological Examination of Water

No.Lab./Tech.(Bact)/2026-27/ 01 / 38

Date :
08 /04 /2026

To,
Principal ,
Mount View Sr. Sec. School , Airport Road, Bedwas ,
Udaipur(RAJ.)

District: : UDAIPUR

Reference Sample Collected By School staff
No

The Sample was not
Collected by this Laboratory

Sample No.	Date & Time of Collection	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (Water)
1	06-04-2026	Udaipur (M CI)	R.O. water	Tap - R.O. Water - Mount View Sr. Sec. School - Bedwas	-	Nil	Potable

Not Valid for Water
Quality Legal Cases

Superintending Chemist
PHED Laboratory, Udaipur

No.Lab./Tech.(Bact)/2026-27/ 01 /

8/4/2026